

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਜ/ਸ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ-ਮੰਡਲ, ਫਗਵਾੜਾ
ਲੇਬਰ ਕਲੋਨੀ ਇੰਡਸਟਰੀ ਏਰੀਆ ਫਗਵਾੜਾ , sdewssphgpb@gmail.com

To,

PRINCIPAL,
SAINT SOLIDIER SCHOOL,
HAIDIABAD, PHAGWARA.

No. 03

Date: 02/04/2026

**Subject: Issue Sanitary Certificate for PRINCIPAL, SAINT SOLIDIER SCHOOL,
HAIDIABAD, PHAGWARA**

It is Certified that PRINCIPAL, SAINT SOLIDIER SCHOOL, HAIDIABAD, PHAGWARA Tehsil Phagwara District Kapurthala has safe drinking water as per Water Testing Report No. DWTLKPT/2627/00001 Dated: 02-04-2026 by the Water Testing Laboratory Kapurthala and sanitation condition in the school building as per the norms prescribed by the DWSS. This certificate is valid for one year after issue date.


Sub Divisional Engineer,
Water Supply & Sanitation,
Sub Division Phagwara



TEST REPORT

Name & Address of Customer : S.D.E W/S & SANITATION SUB DIV PHAGWARA KPT KAPURTHALA		Customer Reference No.	No : 1411 Dated : 27/03/2026
		Sample Submitted by	SARABJIT SINGH S.D.E
		Date of Sample Receipt	01/04/2026
		Analysis Starting Date	01/04/2026
		Analysis completion Date	02/04/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC144592600000125F	Sample Type :	Water
Test Report No.:	DWTLKPT/2627/00001	Date of Issue :	02/04/2026
Registration no.:	DWTLKPT/REG2627/00001	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	SAINT SOLIDIER SCHOOL HAIDIABAD / HA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Phagwara	District :	Kapurthala
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.99	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrode Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 - 2022) (Sensory Method)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 6 - 2022)
5	TDS	86	500	2000	mg/l	IS 3025 (Part 15-2023) Gravimetric Method
6	Turbidity	0.50	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	36.18	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	28.00	200	600	mg/l	IS 3025 (Part 21-2023) EDTA Method
9	Calcium(Ca)	8.01	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	1.94	30	100	mg/l	APHA (24th Ed-2023) Method 3500-Mg-2.3 By Calculation Method
11	Chloride(Cl)	5.99	250	1000	mg/l	IS 3025 (Part 32-2023) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviations used: TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, E = Initial Standard, NA = Not Applicable, NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total.
5. * Have not available or test not performed for this parameter.
6. Temperature condition limit: 25±2°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By

Mr. Jyesh Kumar
Microbiologist/Analyst
Authorized Signatory
For District Water Testing Laboratory
Kapurthala

End of the Test Report